LED Emergency Exit Sign – Wall or Ceiling Mount

A slim, maintained LED exit sign with battery backup for wall or ceiling mounting in offices, shops, schools and warehouses.



KEY FEATURES

- Maintained – lit all the time, stays lit when the power fails
- Lithium iron phosphate (LiFePO4) backup battery
- Single or double sided – 4 decals included
- Wall or ceiling mounting bracket with security lock
- Test button and green charge light
- Low 3 W running power

IN THE BOX

- 1 × LED exit sign
- 1 × mounting bracket
- 4 × decals: 2 × running man, 1 × left arrow, 1 × right arrow

SPECIFICATIONS

Power	3 W
Input voltage	220–240 V AC, 50/60 Hz
Mode	Maintained
Battery	Long lifeLiFePO4 (lithium iron phosphate), 3.2 V 600 mAh
Emergency duration	More than 2 hours (120 min)
Charging time	16 hours
Emergency classification	C0: D4, C90: D3.2
Viewing distance	24 m
Light colour	6000 K
IP rating	IP20 (indoors only)
Size	358 × 211 × 62.5 mm
Weight	0.8 kg
Material	Flame-retardant polycarbonate, white housing
Operating temperature	0 °C to +40 °C
Approvals	Certified to AS 60598.2.22 and AS/NZS 2293.3
Warranty	2 years (sign), 1 year (battery)

Installation: licensed electrician required – see the installation guide. Keep your invoice for warranty.

LED Emergency Exit Sign – Wall or Ceiling Mount

ABOUT THIS PRODUCT

A slim maintained LED exit sign that stays lit all the time and keeps glowing when the power fails, guiding people safely out. It mounts on a wall or ceiling and can be single or double sided, with running man and arrow decals included. A lithium iron phosphate battery gives more than 2 hours of backup, and a test button and charge light make routine checks easy. At just 3 W it is cheap to run, ideal for offices, shops, schools, gyms and warehouses.

MORE DETAILS

Supply	Connect to an unswitched active
Light source	3 W LED strip
Electrical class	Class I
Rated ambient	ta 40 °C
Bracket	Security lock holds the sign in its bracket

SAFETY & COMPLIANCE

Electrical safety certified for Australia
Certificate GMA-520254, valid to 18 Sep 2029

RCM

Electrical safety certificate	GMA-520254 (valid to 18 Sep 2029)
Certificate covers	The exit sign
Compliance mark	RCM (Regulatory Compliance Mark) for electrical safety and EMC
Equipment risk level	Level 1
Tested to	AS 60598.2.22:2019; AS/NZS 60598.1:2017 + A1 - 2
Also	Complies with AS 61347.2.7 2019 (per certificate)
Also	Complies with AS/NZS 2293.3 2018 (per certificate)
Also	Class I, IP20, ta 40 °C (per certificate)

Greenhse Technologies is the registered Australian responsible supplier for this product on the national Electrical Equipment Safety System (EESS). Certificate numbers can be checked on the public EESS database at eess.gov.au.